

RECEIVED

JAN 12 2017

WATER RESOURCES STATE ENGINEER COLO

Well Permit Number: 298713 Receipt Number:
Owner's Well Designation:
Well Owner Name: Stafford land and cattle
Well Location Street Address:

PS Well Location: Zone 12 Zone 13 Easting: 475963 Northing: 4220638 County: STATE ENGINEER COLO
Legal Well Location: 1/4, 1/4, Sec., 13 Twp. 22 N or S Range 70 E or W 6th P
Distances from Section Lines: ft. from N or S section line, and ft. from E or W section line
Division: eagle springs ranch, Lot 31, Block, Filing (Unit) 2

Ground Surface Elevation: feet Date Completed: Drilling Method:
Completed Aquifer Name: 11/09/2015 Total Depth: 260 feet Depth Completed: 260 feet
Advance Notification: Was Notification Required Prior to Construction? Yes No, Date Notification Given:

Aquifer Type: Type I (One Confining Layer) Type I (Multiple Confining Layers) Laramie-Fox Hills
(Type II) (Not overlain by Type III) (Type II) (Overlain by Type III) Type III (alluvial/colluvial)

Geologic Log table with columns: Depth, Type, Grain Size, Color, Water Loc.
Rows include: 0-10 top soil brown, 10-38 clay tan, 38-260 granite black, and a row with 170 in Water Loc.

12. Hole Diameter (in.) table with columns: From (ft), To (ft)
Rows: 9 0-39, 6 1/8 39-260

13. Plain Casing table with columns: OD (in), Kind, Wall Size (in), From (ft), To (ft)
Rows: 6 5/8 steel .188 1-39, 4 1/2 pvc scv 40 20-180

Perforated Casing table with columns: OD (in), Kind, Wall Size (in), From (ft), To (ft)
Row: 4 1/2 pvc scv 40 180-260

14. Filter Pack:
Material
Size
Interval

15. Packer Placement:
Type
Depth

16. Grouting Record table with columns: Material, Amount, Density, Interval, Place
Row: cement 6bags 6-1 0-39 pou

Remarks:

Disinfection: Type chlorox Amt. Used 6 cups

Well Yield Estimate Data: Check box if Test Data is submitted on Form Number GWS-39, Well Yield Test Re

Well Yield Estimate Method: air

Static Level: 160 Estimated Production Rate 83 gpm.

Date/Time measured: 11/09/15 Estimate Length (hrs) 2

Remarks:

I have read the statements made herein and know the contents thereof, and they are true to my knowledge. This document is signed (or name entered online) and certified in accordance with Rule 17.4 of the Water Well Construction Rules, 2 CCR 402.2. The filing of a document that contains false statements is a violation of section 37-91-108(1)(e), C.R.S., and is punishable by fines up to \$1,000 and/or revocation of the contracting license. If filing on late Engineer considers the entry of the licensed contractor's name to be compliance with Rule 17.4.

Company Name: Key Drilling Email: larryfinneydrilling@gmail.com Phone w/area code: 719-275-9525 License Number: 1358

Address: 1124 eagles nest ct canon city co 81212